

Contact person

Maria Rådemar

Division Materials and Production

+46 10 516 51 65

maria.rademar@ri.se

Date

2025-02-19

Reference

O100785-1302536

Page

1 (2)

Jotun A/S

Postboks 2021

NO-3235 SANDEFJORD

Summary of emission tested products

A summary of emission tested products that meet the chemical requirements of M1 Emission Classification of Building Materials.

The limit values of M1:

Chemical:	
TVOC	$\leq 0.2 \text{ mg/m}^2\text{h}$
Carcinogens	$\leq 0.001 \text{ mg/m}^2\text{h}$
Formaldehyde	$\leq 0.05 \text{ mg/m}^2\text{h}$
Ammonia	$\leq 0.03 \text{ mg/m}^2\text{h}$
Single VOC	$\leq \text{EU-LCI } \mu\text{g/m}^3$
Sensory:	
Sensory acceptability	$\geq + 0.0$

The following products are tested and meet the chemical limit values of M1:

1	JOTAPROFF Prima Clean
2	JOTAPROFF Prima Air
3	JOTAPROFF Prima Wall 05
4	JOTAPROFF Prima Wall 07
5	JOTAPROFF Prima Wall 10
6	JOTAPROFF Prima Wall 25
7	JOTAPROFF Primadekk 02
8	JOTAPROFF Flow
9	JOTAPROFF Dynamic
10	JOTAPROFF Prosjekt Støvbinder Hvit
11	JOTAPROFF Prosjekt Støvbinder Klar
12	JOTAPROFF Grunning
13	LADY Pure Color
14	LADY Wonderwall
15	LADY Aqua Matt
16	LADY Balance
17	LADY Supreme Finish Pure matt

RISE Research Institutes of Sweden AB

Postal address

Box 857
501 15 BORÅS
SWEDEN

Office location

Brinellgatan 4
504 62 Borås
SWEDEN

Phone / Fax / E-mail

+46 10-516 50 00
+46 33-13 55 02
info@ri.se

Confidentiality level

C2 - Internal

This document may not be reproduced other than in full, except with the prior written approval of RISE Research Institutes of Sweden AB.

18	LADY Supreme Finish Silkematt
19	LADY Supreme Finish Halvblank
20	LADY Supreme Finish Superblank
21	JOTUN Kvist og Sperregrunning
22	JOTUN Heftgrunning Universal
23	JOTUN Grunning for tapet
24	JOTUN Grunning for Våtrom
25	JOTUN Sparkel Vegg&Tak Medium (Ammonia not tested)

RISE Research Institutes of Sweden AB
Chemistry and Applied Mechanics - Chemical Product Safety

Performed by

Maria Rådemar

Verification

Transaction 09222115557539574391

Document

Assessment M1 products

Main document

2 pages

Initiated on 2025-02-19 11:19:02 CET (+0100) by Maria Rådemar (MR)

Finalised on 2025-02-19 11:19:02 CET (+0100)

Signatories

Maria Rådemar (MR)

RISE Research Institutes of Sweden AB

Company reg. no. 556464-6874

maria.rademar@ri.se

Signed 2025-02-19 11:19:02 CET (+0100)

This verification was issued by Scrive. Information in italics has been safely verified by Scrive. For more information/evidence about this document see the concealed attachments. Use a PDF-reader such as Adobe Reader that can show concealed attachments to view the attachments. Please observe that if the document is printed, the integrity of such printed copy cannot be verified as per the below and that a basic print-out lacks the contents of the concealed attachments. The digital signature (electronic seal) ensures that the integrity of this document, including the concealed attachments, can be proven mathematically and independently of Scrive. For your convenience Scrive also provides a service that enables you to automatically verify the document's integrity at: <https://scrive.com/verify>

